

Magnus Larsson  
Danfoss Värmepumpar AB  
Box 950  
671 29 ARVIKA  
Sweden

## Test of air-to-water heat pump for EN 14825

(8 appendices)

### Work requested

Testing of an air-to-water heat pump in accordance to EN14825:2013, to determine the seasonal coefficient of performance, SCOP. The heat pump was tested for the average climate, and for both low temperature and high temperature applications. Additional test conditions according to EN 14511 were also performed.

### Item for testing

Type of heat pump:	Air/Water, fixed capacity type, new heat pump
Manufacturer:	Danfoss Värmepumpar AB
Type designation:	Thermia Atec HP 13
Serial number, heat pump:	086U936326482593
Cold heat transfer medium:	Air
Warm heat transfer medium:	Water
Refrigerant:	R407C, 5.1 kg
Dimensions (width x depth x height):	1016x 564 x 1477 mm
Weight (empty):	155 kg

The heat pump was delivered from the manufacturer to SP's test laboratory in February 2014. No damage could be seen on the unit when visually inspected.

### Place and date of testing

The heat pump was installed by SP following the instructions from the manufacturer. The heat pump was tested at SP at the department of Energy Technology during May to June 2014.

### Test methods

The space heating performance of the heat pump was tested in accordance with EN 14825:2013, EN 14511-2:2013 and EN 14511-3:2011. Testing and rating at part load conditions, calculation of seasonal performance and determination of the energy consumption at thermostat off mode, standby mode, off mode, crankcase heater mode and compressor off mode were carried out in accordance with EN 14825:2013. Performance testing was performed for the standard European climate, as defined in EN 14825, average (A) at test points as shown in table 1 and table 2. The heat pump has variable outlet temperature, and a heat curve based on the outdoor temperature. For the test points where the heat pump's heating capacity is higher than what is required, the outlet temperature during the performance test is corrected according to eq. 15 in EN 14825 and the coefficient of performance is corrected, in accordance

---

#### SP Technical Research Institute of Sweden

Postal address  
SP  
Box 857  
SE-501 15 BORÅS  
Sweden

Office location  
Västeråsen  
Brinellgatan 4  
SE-504 62 BORÅS

Phone / Fax / E-mail  
+46 10 516 50 00  
+46 33 13 55 02  
info@sp.se

Laboratories are accredited by the Swedish Board for Accreditation and Conformity Assessment (SWEDAC) under the terms of Swedish legislation. This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

to EN 14825, using a degradation coefficient, Cc. Heating load less than 100% of the building's heating demand is referred to as part-load ratio.

**Table 1** Space heating performance testing and part-load ratio in accordance with table 12 presented in EN 14825 for seasonal performance calculations for average climate (A) and low temperature application.

Average			Outdoor heat exchanger	Indoor heat exchanger
Test point	Part-load ratio <sup>1</sup>	Part-load ratio %	Outdoor air	Inlet/outlet temperatures
			Inlet dry bulb (wet bulb) temperature, °C	Variable outlet °C
A	$(-7-16)/(T_{\text{designh}}^2-16^3)$	88	-7(-8)	<sup>a</sup> /34
B	$(+2-16)/(T_{\text{designh}}-16)$	54	2(1)	<sup>a</sup> /30
C	$(+7-16)/(T_{\text{designh}}-16)$	35	7(6)	<sup>a</sup> /27
D	$(+12-16)/(T_{\text{designh}}-16)$	15	12(11)	<sup>a</sup> /24
E	$(\text{TOL} -16)/(T_{\text{designh}}-16)$		TOL	Variable outlet shall be calculated by interpolation or extrapolation from the temperatures which are closest to the TOL. <sup>a</sup>
F	$(T_{\text{biv}}^4-16)/(T_{\text{designh}}-16)$		T <sub>biv</sub>	Variable outlet shall be calculated by interpolation from the upper and lower temperatures which are closest to the bivalent temperature.

<sup>1</sup> Formula for calculating the part-load ratio of the building's maximum heating load at a specific temperature condition

<sup>2</sup> Reference design temperature condition for heating, T<sub>designh</sub> = -10°C for average climate

<sup>3</sup> Outdoor air dry bulb temperature, at this temperature the building's heating demand is zero

<sup>4</sup> Lowest outdoor air dry bulb temperature at which the heat pump is capable of covering the total heating demand of the building, T<sub>biv</sub> = +2°C maximum value for average climate

<sup>a</sup> With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 30/35 conditions

**Table 2** Space heating performance testing and part-load ratio in accordance with table 18 presented in EN 14825 for seasonal performance calculations for average climate (A) and high temperature application.

Average			Outdoor heat exchanger	Indoor heat exchanger
Test point	Part-load ratio <sup>1</sup>	Part-load ratio %	Outdoor air	Inlet/outlet temperatures
			Inlet dry bulb (wet bulb) temperature, °C	Variable outlet °C
A	$(-7-16)/(T_{\text{designh}}^2-16^3)$	88	-7(-8)	<sup>a</sup> /52
B	$(+2-16)/(T_{\text{designh}}-16)$	54	2(1)	<sup>a</sup> /42
C	$(+7-16)/(T_{\text{designh}}-16)$	35	7(6)	<sup>a</sup> /36
D	$(+12-16)/(T_{\text{designh}}-16)$	15	12(11)	<sup>a</sup> /30
E	$(\text{TOL} - 16)/(T_{\text{designh}}-16)$		TOL	Variable outlet shall be calculated by interpolation or extrapolation from the temperatures which are closest to the TOL. <sup>a</sup>
F	$(T_{\text{biv}}^4-16)/(T_{\text{designh}}-16)$		T <sub>biv</sub>	Variable outlet shall be calculated by interpolation from the upper and lower temperatures which are closest to the bivalent temperature.

<sup>1</sup> Formula for calculating the part-load ratio of the building's maximum heating load at a specific temperature condition

<sup>2</sup> Reference design temperature condition for heating, T<sub>designh</sub> = -10°C for average climate

<sup>3</sup> Outdoor air dry bulb temperature, at this temperature the building's heating demand is zero

<sup>4</sup> Lowest outdoor air dry bulb temperature at which the heat pump is capable of covering the total heating demand of the building, T<sub>biv</sub> = +2°C maximum value for average climate

<sup>a</sup> With the water flow rate as determined at the standard rating conditions given in EN14511-2 at 47/55 conditions

The space heating performance of the heat pump was also tested in accordance with EN 14511 and the certification reference HARP, at test points as shown in table 3. Results, with measured and calculated data shown in tabular form, are found in appendix 4.

**Table 3.** Test conditions for space heating test in accordance to EN 14511 and HARP

Test point	Inlet dry bulb (wet bulb) temperature, °C	Warm heat transfer medium, inlet/outlet temperature, °C
<b>A7/W35</b>	7(6)	30/35
<b>A2/W35</b>	2(1)	a/35
<b>A7/W45</b>	7(6)	40/45

a: Tested with heat transfer media flow rates obtained at test condition A7/W35

### Test equipment

The following test equipment was used:

Name	SP inventory no.
Test rig	LV3
Data acquisition system	900 071, 201 417
Electric power meter	901 996
Flow meters	701 277
Differential pressure sensors	202 865
Dew point sensor	200 428
Resistive temperature sensors, Pt 100.	-

### Heat pump settings for the space heating performance tests

The heat pump was installed by personnel from SP following the instructions from the manufacturer. The following settings were used during the measurements:

During the performance test maximum heat curve was used to keep the compressor running continuously

There is no internal warm heat transfer medium circulation pump in the unit.

### Results from space heating performance testing

The test results given in this report relate only to the specific item tested and under the specific conditions described, with the specific equipment named and at the specified settings. Calculations are based on the results from the laboratory tests according with EN 14825:2013 which in its turn refers to EN 14511:2011 part 3 in a large scale when denoting the test method. The water flow rate was determined at the standard rating conditions given in EN14511-2:2013 at 30/35 conditions for the low temperature application and at 47/55 conditions for the high temperature application. Results are defined according to EN 14825.

The bivalent temperature,  $T_{biv}$ , was declared by the manufacturer. At  $T_{biv}$  the heat pump is capable of covering the total heating demand of the building. The heating demand of the building,  $P_{designh}$ , is determined by dividing the heating capacity measured at  $T_{biv}$ , by the formula for calculating the part-load ratio at the same temperature condition. For the formula for calculating the part-load ratio see table 1 and 2.

**Table 4**  $T_{bivalent}$  and  $P_{designh}$  for the heat pump tested.

Low temperature application, average climate		High temperature application, average climate	
$T_{biv}$ , °C	$P_{designh}$ , kW	$T_{biv}$ , °C	$P_{designh}$ , kW
-5	10.64	-4	11.03

The unit was tested for test point E at  $-10^{\circ}\text{C}$  for both the low and high temperature application in accordance to EN 14825. EN 14825 states if the declared TOL is lower than  $T_{designh}$ , it may be assumed that TOL is equal to  $T_{designh}$ .

Results from capacity tests

Table 5 below presents the total thermal output power,  $P_H$ , and the corresponding coefficient of performance, COP, at corresponding test points A-F in table 1 and table 2. The values presented are the results from the laboratory tests according with EN 14825 and EN 14511 for the average climate. The operating conditions are presented in table 1 and table 2.

**Table 5** Results from the performance tests<sup>1</sup>.

Test point:	Low temperature application, average climate			High temperature application, average climate		
	$P_H$ (kW)	$P_E$ (kW)	COP	$P_H$ (kW)	$P_E$ (kW)	COP
A	8.05	2.48	3.24	7.61	3.21	2.37
B	9.87	2.56	3.85	10.03	3.09	3.25
C	12.03	2.53	4.75	12.58	2.97	4.23
D	14.99	2.55	5.89	14.82	2.87	5.16
E	7.40	2.48	2.98	6.92	3.30	2.10
F	8.59	2.49	3.45	8.48	3.15	2.70

<sup>1</sup>For the test points where the heat pump’s heating capacity is higher than what is required, the outlet temperature during the performance test was corrected according to eq. 15 in EN14825. Please see Appendix 2 and 3 for measured test data.

Results for measurements of power consumption during modes other than “active mode”

Table 6 below presents the measurements of the energy consumption at thermostat off mode, standby mode, off mode, crankcase heater mode and compressor off mode. The compressor off mode is needed for the calculation of the Cc-factor which is used for recalculation of COP at the test points where the heat pump’s heating capacity is higher than what is required. Compressor off was therefore measured after test points B-D.

**Table 6** Results for power consumption during modes other than active mode

	Low temperature application, average climate	High temperature application, average climate
Thermostat off <sup>1</sup> (W)	81	47
Standby mode (W)	7	7
Off mode (W)	7	7
Crankcase heater mode <sup>1</sup> (W)	0	0
Compressor off <sup>2</sup> (W), For test point:	Low temperature application, average climate	High temperature application, average climate
B	65	30
C	87	37
D	65	73

<sup>1</sup> In accordance to EN 14825 the standby power consumption is deducted from the measured total energy consumption of the unit during thermostat off mode and during crankcase heater mode.

<sup>2</sup> Not defined in EN 14825. However, it is needed when calculating the Cc-factor according to eq.18. According to EN 14825, “The electrical power input during the compressor off state of the unit is measured when the compressor is switched off for at least 10 min.” The heat curve was lowered until the compressor stopped. Corrections were made for power input of liquid pump, according to EN14511-3:2011.

### Results for SCOP

The results obtained from the testing was used to calculate the values of the seasonal coefficient of performance, SCOP, which are presented in table 7. The results are based on the  $T_{biv}$  and  $P_{designh}$  presented in table 4.

**Table 7** SCOP results for low temperature and high temperature applications.

Low temperature application, average climate			High temperature application, average climate		
$T_{biv}$ , °C	$P_{designh}$ , kW	SCOP	$T_{biv}$ , °C	$P_{designh}$ , kW	SCOP
-5	10.64	3.82	-4	11.03	3.23

More detailed presentations of the tests, with measured and calculated results shown in tabular form, are found in appendix 1, 2 and 3.

**SP Technical Research Institute of Sweden**  
**Energy Technology - Building Services Engineering**

Performed by

Examined by

Helena Nakos

Johan Larsson

### **Appendices**

1. Result, technical data sheet in accordance to EN 14825
2. Result space heating performance testing, low temperature application
3. Result, space heating performance testing, high temperature application
4. Results, space heating performance testing in accordance with EN 14511 and the certification reference HARP
5. List of components
6. Photographs
7. Uncertainty of measurement
8. Nomenclature

## Appendix 1

**Results, technical data sheet in accordance to EN 14825**

Model name	Thermia ATEC HP 13				
				Low temp. application	High temp. application
Function	Heating		Average "A"	Yes	
Capacity control	Fixed			Yes	
Design load	Heating	Average	P <sub>designh</sub> , kW	10.64	11.03
Seasonal Efficiency	Heating	Average	SCOP <sub>on</sub> <sup>1</sup>	3.86	3.26
			SCOP <sub>net</sub> <sup>2</sup>	3.94	3.35
			SCOP <sup>3</sup>	3.82	3.23
Heating capacity at outdoor temperature T <sub>j</sub>	Heating, Average	T <sub>j</sub> = -7 °C	P <sub>H</sub> , kW	8.05	7.61
		T <sub>j</sub> = 2 °C	P <sub>H</sub> , kW	9.87	10.03
		T <sub>j</sub> = 7 °C	P <sub>H</sub> , kW	12.03	12.58
		T <sub>j</sub> = 12 °C	P <sub>H</sub> , kW	14.99	14.82
		T <sub>j</sub> = bivalent temperature, °C	P <sub>H</sub> , kW	8.59	8.48
		T <sub>j</sub> = operation limit, -10 °C	P <sub>H</sub> , kW	7.40	6.92
Coefficient of performance for heating at outdoor temperature T <sub>j</sub>	Heating, Average	T <sub>j</sub> = -7 °C	COP	3.24	2.37
		T <sub>j</sub> = 2 °C	COP	3.85	3.25
		T <sub>j</sub> = 7 °C	COP	4.75	4.23
		T <sub>j</sub> = 12 °C	COP	5.89	5.16
		T <sub>j</sub> = bivalent temperature, °C	COP	3.45	2.70
		T <sub>j</sub> = operation limit, -10 °C	COP	2.98	2.10
Bivalent temperatures	Heating, Average	T <sub>bivalent</sub> , °C		-5	-4
Operation limit temperatures	Heating, Average	TOL, °C		-10 <sup>4</sup>	-10 <sup>4</sup>
Seasonal electricity consumption	Heating, Average	QHE/A, kW/a		3900	4775
Modes other than "active mode"	Off-mode <sup>5</sup> , W			7	7
	Standby mode <sup>6</sup> , W			7	7
	Thermostat-off mode <sup>7</sup> , W			81	47
	Crankcase heater mode <sup>8</sup> , W			0	0
Contact details for obtaining more information	Name manufacturer		Danfoss Värmepumpar AB		
	Address		Snickaregatan 1 671 34 Arvika Sweden		

## Appendix 1

- <sup>1</sup> SCOP<sub>on</sub> is the heat pump's average seasonal performance in active mode, presenting the hours the heat pump's heating performance is activated
- <sup>2</sup> SCOP<sub>net</sub> is the heat pump's average seasonal performance in active mode excluding electricity consumption for thermostat off, standby, off mode, crankcase heating mode and that of an electrical back up heater
- <sup>3</sup> SCOP is the units total seasonal performance factor representing the whole heating season
- <sup>4</sup> Set to the same value as T<sub>designh</sub>
- <sup>5</sup> A mode where the unit is completely switched off and is not capable to be reactivated by a control device or a timer
- <sup>6</sup> A mode where the unit is partially switched off and can by a control device or timer be reactivated
- <sup>7</sup> A mode corresponding to the hours with no heating load, but where the heating function of the unit is switched on but the unit is not operational as there is no heating load
- <sup>8</sup> A mode corresponding to the hours where a heating device is activated to avoid refrigerant to migrating to the compressor in order to limit the refrigerant concentration in oil at compressor start



## Appendix 2

## Results, space heating performance in accordance to EN 14825, average climate and low temperature application

Operating point		<b>I</b>	<b>A</b>	<b>B</b>	<b>C</b>	<b>D</b>	<b>E</b>	<b>F</b>
		30/35	-/34	27.7/-	25.5/-	23.4/-	-/35	-/33.1
	°C	7/6w	-/8w	2/1w	7/6w	12/11w	-10/-11w	-5/-6w

Data collection period	<i>min</i>	70	70	180	180	70	70	70
Transient		No	No	Yes	Yes	No	No	No

<i>Temperature</i>		°C						
Heat transfer medium, hot, outlet	$t_{w2}$	35.1	34.1	31.6	30.3	29.3	35.1	33.1
Heat transfer medium, hot, inlet	$t_{w1}$	30.0	30.9	27.8	25.6	23.4	32.2	29.7
Dry bulb air temperature	$t_{a5}$	7.1	-7.0	2.1	7.0	12.0	-9.9	-5.0
Wet bulb air temperature	$t_{wb}$	5.9	-8.0	1.0	5.8	11.0	-10.9	-6.0

<i>Flow</i>		$m^3/h$						
Volume flow rate of heat transfer medium. Hot	$q_w$	2.18	2.18	2.18	2.18	2.18	2.18	2.18

<i>Pressure difference</i>		kPa						
Heat transfer medium, hot	$DP_w$	-11.7	-11.7	-11.8	-11.9	-12.0	-11.7	-11.7

<i>Electrical power</i>		kW						
Total	$P_T$	2.736	2.429	2.506	2.479	2.493	2.425	2.434

### Calculated quantities

<i>Thermal power</i>		kW						
Total thermal output power to the heat sink	$P_{Ihps}$	12.708	7.995	9.812	11.980	14.934	7.344	8.538

<i>Coefficient of performance</i>		(-)						
total	$COP_{Ihps}$	4.65	3.29	3.92	4.83	5.99	3.03	3.51

### Correction in accordance with EN 14511

<i>Correction, pump power</i>		W						
Heat transfer medium pump, hot	$P_{epw,s}$	53	53	53	53	54	53	53

<i>Electrical power after correction</i>		kW						
Total	$P_E$	2.789	2.481	2.559	2.532	2.547	2.478	2.487

<i>Thermal power after correction</i>		kW						
delivered	$P_H$	12.760	8.048	9.865	12.033	14.988	7.397	8.591

<i>COP after correction</i>		(-)						
Total	$COP$	4.58	3.24	3.85	4.75	5.89	2.98	3.45

### Heat demand of the house and average outlet temperature according to EN14825

$T_{biv}$	-5°C							
$P_{designh}$	10.64 kW							
$P_{house}$	kW		9.41	5.73	3.68	1.64	10.64	8.59
$T_{out}$ , average according to eq.15 in 14825, °C					30.0	27.0	24.0	

## Appendix 3

## Results, space heating performance in accordance to EN 14825, average climate and high temperature application

Operating point		1	A	B	C	D	E	F
	°C	47/55	-/52	38/-	33.5/-	28.9/-	-/55	-/48.7
		7/6w	-7/-8w	2/1w	7/6w	12/11w	-10/-11w	-4/-5w

Data collection period	<i>min</i>	70	70	180	70	70	70	70
Transient		No	No	Yes	No	No	No	No

<i>Temperature</i>		°C						
Heat transfer medium, hot, outlet	$t_{w2}$	55.1	52.0	44.8	41.9	39.0	55.1	48.8
Heat transfer medium, hot, inlet	$t_{w1}$	47.0	46.9	38.0	33.5	29.0	50.5	43.1
Dry bulb air temperature	$t_{a5}$	7.1	-7.0	2.2	7.1	12.0	-9.9	-4.0
Wet bulb air temperature	$t_{wb}$	5.9	-7.8	1.0	5.9	11.0	-11.0	-5.0

<i>Flow</i>		$m^3/h$						
Volume flow rate of heat transfer medium, Hot	$q_w$	1.29	1.29	1.29	1.29	1.29	1.29	1.29

<i>Pressure difference</i>		kPa						
Heat transfer medium, hot	$DP_w$	-4.1	-4.1	-4.2	-4.3	-4.3	-4.1	-4.1

<i>Electrical power</i>		kW						
Total	$P_T$	3.790	3.194	3.067	2.954	2.855	3.279	3.128

### Calculated quantities

<i>Thermal power</i>		kW						
Total thermal output power to the heat sink	$P_{Thps}$	11.907	7.594	10.012	12.556	14.797	6.902	8.463

<i>Coefficient of performance</i>		(-)						
Total	$COP_{hps}$	3.14	2.38	3.26	4.25	5.18	2.10	2.71

### Correction in accordance with EN 14511

<i>Correction, pump power</i>		W						
Heat transfer medium pump, hot	$P_{epw,s}$	18	18	18	19	19	18	18

<i>Electrical power after correction</i>		kW						
Total	$P_E$	3.808	3.212	3.085	2.973	2.874	3.297	3.146

<i>Thermal power after correction</i>		kW						
delivered	$P_H$	11.925	7.612	10.031	12.575	14.815	6.920	8.481

<i>COP after correction</i>		(-)						
Total	COP	3.13	2.37	3.25	4.23	5.16	2.10	2.70

### Heat demand of the house and average outlet temperature according to EN14825

$T_{biv}$	-4°C							
$P_{designh}$	11.03 kW							
$P_{house}$	kW	9.75	5.94	3.82	1.7	11.03	8.48	
$T_{out}$ , average according to eq.15 in 14825, °C				42.0	36.0	30.1		

## Appendix 4

## Results, space heating performance testing in accordance with EN 14511 and the certification reference HARP

**Operating point**

	30/35	-35	40/45
°C	7/6w	2/1w	7/6w

Data collection period	<i>min</i>	70	117.3	70
Transient		No	Yes	No

<i>Temperature</i>	°C			
Heat transfer medium, hot, outlet	$t_{w2}$	35.1	34.6	45.2
Heat transfer medium, hot, inlet	$t_{w1}$	30.0	30.7	40.1
Dry bulb air temperature	$t_{a5}$	7.1	2.1	7.1
Wet bulb air temperature	$t_{wb}$	5.9	0.8	5.9

<i>Flow</i>	$m^3/h$			
Volume flow rate of heat transfer medium. Hot	$q_w$	2.18	2.18	2.07

<i>Pressure difference</i>	<i>kPa</i>			
Heat transfer medium, hot	$Dp_w$	-11.7	-11.7	-10.4

<i>Electrical power</i>	<i>kW</i>			
Total	$P_T$	2.736	2.627	3.221

**Calculated quantities**

<i>Thermal power</i>	<i>kW</i>			
Total thermal output power to the heat sink	$P_{Thps}$	12.708	9.810	12.215

<i>Coefficient of performance</i>	( - )			
total	$COP_{hps}$	4.65	3.73	3.79

**Correction in accordance with EN 14511**

<i>Correction, pump power</i>	<i>W</i>			
Heat transfer medium pump, hot	$P_{epw,s}$	53	53	47

<i>Electrical power after correction</i>	<i>kW</i>			
Total	$P_E$	2.789	2.680	3.268

<i>Thermal power after correction</i>	<i>kW</i>			
delivered	$P_H$	12.760	9.863	12.262

<i>COP after correction</i>	( - )			
Total	$COP$	4.58	3.68	3.75

Appendix 5

**List of components**

Below information is given by the manufacturer.

<i>Type: Atec 13</i>		<i>Year of production:</i> 2014
<i>Part</i>	<i>Manufacturer, type</i>	<i>Model number</i>
Compressor:	Copeland	ZH30
Expansion valve:	Danfoss	UKV-A191
Evaporator:	Lloyd Coil	4 row
Condenser:	SWEP	B25*50
Refrigerant: (type, charger)	R407C	5.1 Kg
Control system:	Inbuilt controller Software v2.2.1	
Warm heat transfer medium pump:		
Cold heat transfer medium pump:	-	-
Three way valve:		
Subcooler:	-	-
Desuperheater	-	-
Dryer filter:	Danfoss	DMB163s
Sight glass:	-	
High pressure switch:	Saginomya	31 bar
Low pressure switch:	Pressure transmitter 0.4 bar(g)	
DHW tank (type, volume):	Stainless Steel	
Insulation, DHW tank:	Fiberglass	
Back up heater:	Backer	
Fan	EBM-Papst	S3G 630-AC52-55

## Appendix 6

### Photographs



**Figure 1** Heat pump, outdoor unit

Appendix 6



Figure 2 Name plate, outdoor unit

## Appendix 7

## Uncertainty of measurement

The uncertainty of measurement is calculated according EA-4/16 with a coverage factor,  $k = 2$ . The results from testing are based partly on direct measurements and partly on calculations. The estimates apply to the total uncertainties including both systematic and random uncertainties. Unit terms and designations are as given in Appendix 7.

### Measured data

#### *Temperatures*

$t_{wo}, t_{wi}$	$\pm 0.1 \text{ K}$
$t_{wo} - t_{wi}$	$\pm 0.05 \text{ K}$
$t_{a5}$	$\pm 0.15 \text{ K}$
$t_{wb}$	$\pm 0.4 \text{ K}$

#### *Differential pressures*

$\Delta p_w$	$\pm 1 \text{ kPa}$
--------------	---------------------

#### *Flows*

$q_w$	$\pm 1 \%$
-------	------------

#### *Electric Power*

$P_T$	$\pm 0.5 \%$
$P_{\text{auxiliary}}$	$\pm 1 \text{ W}$

### Table values

#### *Density*

$\rho_w$	$\pm 1 \text{ kg/m}^3$	(source: SP REPORT 1994:01)
----------	------------------------	-----------------------------

#### *Specific heat capacity at constant pressure*

$c_{pw}$	$\pm 10^{-4} \text{ kJ/(kg. K)}$	(source: SP REPORT 1994:01)
----------	----------------------------------	-----------------------------

### Calculated data

$P_{1hps}, P_H$	$\pm 2.4 \%$
$COP_{hps}, COP$	$\pm 2.5 \%$

Appendix 8

## Nomenclature

### Designations for EN14825:

SCOP	The units total seasonal coefficient of performance representing the whole heating season
SCOP <sub>on</sub>	The average seasonal coefficient of performance in active mode (presenting the hours the heat pump's heating performance is activated)
SCOP <sub>net</sub>	The average seasonal coefficient of performance in active mode excluding electricity consumption from supplementary electric heater, thermostat off, standby, off mode, and crankcase heating mode

### **P Power**

P<sub>designh</sub> Design load at T<sub>designh</sub> conditions

### **T Temperature**

T<sub>designh</sub> Reference design temperature condition for heating (outdoor air temperature)

T<sub>biv</sub> Bivalent temperature, where the unit is capable of covering 100% of the buildings heating load (outdoor air temperature)

TOL Operation limit temperature

### Designations for capacity tests:

#### Beteckningar

#### Designations

#### **COP Värmefaktor**

#### **Coefficient of performance**

COP Värmefaktor; total; rumsuppvärmning; korrigerad enligt EN 14511

Coefficient of performance; total; space heating; corrected according to EN 14511

COP<sub>hps</sub> Värmefaktor; total. rumsuppvärmning

Coefficient of performance. space heating for heat pump system

#### **P El- och värmeeffekt**

#### **Power: electric (active) or thermal**

P<sub>E</sub> Effekt; el; totalt tillförd till värmepumpsystemet; korrigerad enligt EN 14511

Power; electrical; total input to heat pump system; corrected according to EN 14511

P<sub>H</sub> Effekt; värme; från värmepumpsystem till värmesänka. korrigerad enligt EN 14511

Heating capacity; from heat pump system to heat sink; corrected according to EN14511

P<sub>1hps</sub> Effekt; värme; från värmepumpsystem

Heating capacity; from heat pump



Appendix 8

	till värmesänka	system to heat sink
$P_T$	Effekt; el; totalt tillförd till värmepumpsystemet	Power; electrical; total input to the heat pump system
<b>q</b>	<b>Volymflöde</b>	<b>Volume flow rate</b>
$q_w$	Volymflöde; värmeöverförande medium; varm	Volume flow rate; heat transfer medium; warm
<b>t</b>	<b>Temperatur</b>	<b>Temperature</b>
$t_{amb}$	Temperatur; omgivning	Temperature. ambient
$t_{a5}$	Temperatur; värmeöverförande medium; kall	Temperature; heat transfer medium; cold
$t_w$	Temperatur; värmeöverförande medium; varm	Temperature; heat transfer medium; warm
<b><math>c_p</math></b>	<b>Specifik värmekapacitet</b>	<b>Specific heat capacity</b>
$c_{pw}$	Specifik värmekapacitet. värmeöverförande medium; varm	Specific heat capacity; heat transfer medium; warm
<b><math>\Delta p</math></b>	<b>Differenstryck</b>	<b>Differential pressure</b>
$\Delta p_w$	Differenstryck; yttre; värmeöverförande medium; varm	Differential pressure; external; heat transfer medium; warm
<b><math>\rho</math></b>	<b>Densitet</b>	<b>Density</b>
$\rho_w$	Densitet. värmeöverförande medium; varm	Density; heat transfer medium; warm

## Appendix 8

### Index

amb	Omgivning
c	Värmeöverförande medium; kall
def	Avfrostning
e	Elektrisk
h	Uppladdning
hp	Värmepump
hps	Värmepump system
i	In till värmepump
m	Motor; kompressor
max	Maximal
o	Ut från värmepump
p	Pump
s	Tomgång
s	Standardiserad
t	Tappning varmvatten
w	Värmeöverförande medium; varm
wc	Tappvatten; kall
wh	Tappvatten; varm

### Indices

Ambient
Heat transfer medium; cold
Defrost
Electrical
Heating up period
Heat pump
Heat pump system
Inlet to heat pump
Motor; compressor
Maximum
Outlet from heat pump
Pump
Stand by
Standardised
Draw off sanitary water; warm
Heat transfer medium; warm
Sanitary water; cold
Sanitary water; hot